



### CERTIFICATE OF ANALYSIS

**Customer :** Redeemer Lutheran Nursery  
2309 Route 70 East  
Manchester Twp, NJ 08759

**Project ID :** Lead and Copper Samples  
**PAS Project ID :** P22-08069

**Matrix :** Drinking Water  
**Report Date :** 8/1/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-08069-01	Field Blank	Copper	ND	ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:00	7/27/22 11:59
P22-08069-01	Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/24/22 17:00	7/29/22 13:15
P22-08069-02	#3 Hall Water Fountain	Copper	664	ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:02	7/27/22 12:00
P22-08069-02	#3 Hall Water Fountain	Lead	<b>125</b>	ug/L	10	20.0	8.99	15.0 *	SM 3113 B	7/24/22 17:02	7/29/22 14:56
P22-08069-03	#4 Kitchen Sink	Copper	227	ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:04	7/27/22 12:01
P22-08069-03	#4 Kitchen Sink	Lead	3.76	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/24/22 17:04	7/29/22 13:27
P22-08069-04	#1 Right Boys Room Sink	Copper	456	ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:05	7/27/22 12:02
P22-08069-04	#1 Right Boys Room Sink	Lead	14.9	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/24/22 17:05	7/29/22 13:31
P22-08069-05	#2 Right Girls Room Sink	Copper	435	ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:07	7/27/22 12:03
P22-08069-05	#2 Right Girls Room Sink	Lead	<b>42.4</b>	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	7/24/22 17:07	7/29/22 15:00
P22-08069-06	#5 Portable Sink	Copper	28.7	J ug/L	1	50.0	22.6	1300 *	SM 3111 B	7/24/22 17:08	7/27/22 12:04
P22-08069-06	#5 Portable Sink	Lead	1.03	J ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/24/22 17:08	7/29/22 13:39

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result  
\* Federal Action Level

All samples are analyzed in accordance with New Jersey Department of Environmental Protection Protocol

Mark D. Feitelson, Lab. Director